

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Aaron Olver, Secretary

September 13, 2010

REVISED

MUELLER INDUSTRIES CHRIS MUELLER 8285 TOURNAMENT DR STE 150 MEMPHIS TN 38125

Re: Description: FITTINGS, COPPER-ALTERNATE SYSTEM

Manufacturer: MUELLER INDUSTRIES

Product Name: STREAM TECH; ADHESIVE JOINING SYSTEM FOR COPPER

Model Number(s): FITTINGS 1/2" THROUGH 4"

SEE ATTACHMENT A FOR A COMPLETE LIST OF FITTINGS

Product File No: 20090040

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.40 (8) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may only be used on copper that complies with ASTM B88.
- The fittings must be labeled with the size and manufacturer's name or trademark.
- This product shall be installed in accordance to manufacture's specifications.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742

Fax: 608-267-9566

E-mail: jerry.thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 09004005.DOC